

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1130:165 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: *Honeywell International Inc, 1500 W. Dundee Road, Arlington Heights. IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models XLS-1Z1, -1Z1-R, -1Z1-220, -2Z1, -2Z1-R, AND -2Z1-220, "XLS10" Series 1 & 2
Zones fire alarm control units. Local, auxiliary, central station, remote station, automatic, manual, waterflow and sprinkler supervisory service. System components:

MODELS	DESCRIPTION
RCT(-1)	Relay-City Tie (FDR) Module
DL-1	Dialer Module (DACT)
RTUDR	Remote Trouble Unit Driver

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Maximum Retard/Reset/Restart period of fire alarm verification must be adjusted to 30 seconds or less.

XLf: 7165-1388:179

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**